

Information requirements (air-to-air air conditioners)							
Model(s):DOS100GMVCOMPACT3							
Outdoor side heat exchanger of air conditioner	air						
Indoor side heat exchanger of air conditioner	air						
Type	compressor driven vapour compression						
If applicable: driver of compressor	electric motor						
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Rated cooling capacity	$P_{rated,c}$	25.11	kW	Seasonal space cooling energy efficiency	$\eta_{s,c}$	201.0	%
Declared cooling capacity for part load at given outdoor temperatures T_j and indoor $27^{\circ}/19^{\circ}$ °C (dry/wet bulb)				Declared energy efficiency ratio or gas utilisation efficiency/auxiliary energy factor for part load at given outdoor temperatures T_j			
$T_j = +35^{\circ}$ °C	P_{dc}	25.11	kW	$T_j = +35^{\circ}$ °C	EERd	2.46	-
$T_j = +30^{\circ}$ °C	P_{dc}	17.72	kW	$T_j = +30^{\circ}$ °C	EERd	4.01	-
$T_j = +25^{\circ}$ °C	P_{dc}	11.64	kW	$T_j = +25^{\circ}$ °C	EERd	5.87	-
$T_j = +20^{\circ}$ °C	P_{dc}	5.96	kW	$T_j = +20^{\circ}$ °C	EERd	7.49	-
Degradation co-efficient for air conditioners(*)	C_{dc}	0.25	—				-
Power consumption in modes other than 'active mode'							
Off mode	P_{OFF}	0.003	kW	Crankcase heater mode	P_{CK}	0	kW
Thermostat-off mode	P_{TO}	0	kW	Standby mode	P_{SB}	0.003	kW
Other items							
Capacity control	variable			For air-to-air air conditioner: air flow rate, outdoor measured	—	11000	m^3/h
Sound power level, outdoor	L_{WA}	71.0/79.0	dB				
If engine driven: Emissions of nitrogen oxides	$NO_x(**)$	-	mg/kWh fuel input GCV				
GWP of the refrigerant	2088		kg CO ₂ eq (100 years)				
(*) If C_{dc} is not determined by measurement then the default degradation coefficient air conditioners shall be 0,25. (**) From 26 September 2018. Where information relates to multi-split air conditioners, the test result and performance data may be obtained on the basis of the performance of the outdoor unit, with a combination of indoor unit(s) recommended by the manufacturer or importer.							

Information requirements (heat pump)							
Model(s):DOS100GMVCOMPACT3							
Outdoor side heat exchanger of heat pump	air						
Indoor side heat exchanger of heat pump	air						
Indication if the heater is equipped with a supplementary heater	no						
If applicable: driver of compressor	electric motor						
Parameters declared for	Average climate condition						
Item	symbol	value	unit	Item	symbol	value	unit
Rated heating capacity	$P_{rated,h}$	27.50	kW	Seasonal space heating energy efficiency	$\eta_{s,h}$	149.8	%
Declared heating capacity for part load at indoor temperature 20 °C and outdoor temperature T_j				Declared coefficient of performance or gas utilisation efficiency/auxiliary energy factor for part load at given outdoor temperatures T_j			
$T_j = -7$ °C	P_{dh}	14.31	kW	$T_j = -7$ °C	COP_d	2.51	-
$T_j = +2$ °C	P_{dh}	8.57	kW	$T_j = +2$ °C	COP_d	3.79	-
$T_j = +7$ °C	P_{dh}	5.58	kW	$T_j = +7$ °C	COP_d	4.68	-
$T_j = +12$ °C	P_{dh}	6.91	kW	$T_j = +12$ °C	COP_d	6.49	-
T_{biv} = bivalent temperature	P_{dh}	14.31	kW	T_{biv} = bivalent temperature	COP_d	2.51	-
T_{OL} = operation limit	P_{dh}	16.41	kW	T_{OL} = operation limit	COP_d	2.22	-
For air-to-water heat pumps: $T_j = -15$ °C (if $T_{OL} < -20$ °C)	P_{dh}	-	kW	For water-to-air heat pumps: $T_j = -15$ °C (if $T_{OL} < -20$ °C)	COP_d	-	%
Bivalent temperature	T_{biv}	-7	°C	For water-to-air heat pumps: Operation limit temperature	T_{ol}	-10	°C
Degradation co-efficient heat pumps(**)	C_{dh}	0.25	—				
Power consumption in modes other than 'active mode'				Supplementary heater			
Off mode	P_{OFF}	0.003	kW	Back-up heating capacity (*)	el_{bu}	0	kW
Thermostat-off mode	P_{TO}	0.003	kW	Type of energy input	-		
Crankcase heater mode	P_{CK}	0	kW	Standby mode	P_{SB}	0.003	kW
Other items							
Capacity control	variable			For air-to-air heat pumps: air flow rate, outdoor measured	—	11000	m^3/h
Sound power level, indoor/outdoor measured	L_{WA}	72.0/81.0	dB				
Emissions of nitrogen oxides (if applicable)	$NO_x(***)$	-	mg/kWh input GCV	For water/brine-to-air heat pumps: Rated brine or water flow rate, outdoor side heat exchanger	—	-	m^3/h
GWP of the refrigerant	2088		kg CO ₂ eq (100 years)				
(*)							
(**) If C_{dh} is not determined by measurement then the default degradation coefficient of heat pumps shall be 0,25.							
(***) From 26 September 2018.							
Where information relates to multi-split heat pumps, the test result and performance data may be obtained on the basis of the performance of the outdoor unit, with a combination of indoor unit(s) recommended by the manufacturer or importer.							